Town of Epping, NH

Incorporated 1741

Water & Sewer Commissioners 157 Main Street Epping, NH 03042

Water & Sewer Administrator 603-679-5441 x108

WATER & SEWER COMMISSION MEETING MINUTES July 11, 2023

Attendance:

Chairman Tom Dwyer, Commissioner Marc Nickerson, Commissioner Scott Pim W&S Administrator Dennis Koch, Town Administrator Jake Roger.

1. Call to Order:

Chairman Dwyer called the meeting to order at 7:00 PM in the Epping Town Hall.

The Pledge of Allegiance to the Flag followed.

- 2. Approval of Minutes: Motion by Commissioner Nickerson to approve the minutes of June 6 & 26, 2023 as submitted. Seconded by Chairman Dwyer & Commissioner Pim. Motion carried 2-0 for each.
- **3. Appointments: Austin Turner** came in to discuss 46 Martin Road. We are getting two new trains installed this year. We will probably need to go one full year before DES grants permission for new connections. Discussion of probable sewer availability followed. We should have a Warrant Article next March for a large WWTF upgrade. Water?... D2 is fixed, we are starting to permit F1. We are also looking elsewhere for water. We will look at our water budget soon, AT is starting test wells soon on their site.
- **4. Administrator's Report:** Dennis Koch presented a PO for Amtech relining the dip tanks for \$35,360.

Motion by Commissioner Nickerson to approve the PO to Amtech for \$35,360. Seconded by Commissioner Pim. Motion carried 3-0.

Abatement request for 40 Pleasant Street for \$293.01.

Motion by Chairman Dwyer to approve the abatement, seconded by Commissioner Nickerson. Commissioner Pim voted nay. Motion carried 2-1.

We received only one quote for insulating the re-circ. Line. No motion taken, board would like 1-2 more bids please.

Talking to Moonshot about future needs for help. They could review the Zenon purchase and installation and give an opinion.

5. Operator's Report: Anthony submitted an operator's report. All membranes are up and running. We are currently treating all the influent.

RMM has completed the heat trace in the re-circ line and begun diamond plating the grit chamber.

6. Commissioner's Reports:

Chairman Dwyer: No.

Commissioner Nickerson: No.

Commissioner Pim: Would like Anthony to clean up the spreadsheet reports.

TA Roger: Would like a Synagro update for the BOS next meeting.

Motion to adjourn made by Commissioner Nickerson. Seconded by Commissioner Pim. Motion carried $\mathbf{3}-\mathbf{0}.$

Meeting adjourned at 8:00 pm.

Respectfully Submitted

Dennis W. Koch Jr. Water & Sewer Administrator

Minutes approved:

Tom Dwyer, Chairman

Marc Nickerson, Commissioner

Scott Pim, Commissioner